



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2024993  
Permit # 00987-2015UPG  
Request Rec'd 09/16/2015  
Amended Date  
Approval Date 9/16/2015 DS  
Permit Expires 3/16/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|  |   |
|--|---|
| <p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Vinaycka Hospitality<br/>3000 Warrenville Rd.<br/>Lisle, IL 60532</p> <p>Contact: Nick Spizzirri (630) 577-6026</p> | <p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Sheraton Lisle Hotel<br/>3000 Warrenville Rd<br/>Lisle, IL 60532</p> <p>Contact: Nick Spizzirri (630) 577-6026</p> |
|--|---|

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1) - 550*

*(b) Type of tanks:*

*(c) Type of piping: (TK # 1) Piping - Other elbow fitting*

*(d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES : Work includes uncovering the tank at the piping connection. Unhook the existing piping from the tank, remove existing suction stub, Install new foot valve on suction stub, reinstall suction stub with new foot valve, air test primary piping for leaks, backfill and resurface**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Accurate Tank Construction  
204 Poplar Place  
North Aurora, IL 60542

Contact Person: Jason Reed  
Phone: (630) 318-1813  
Contractor Registration # IL002360 Exp. 8/28/2016

---

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File