



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2007084
Permit # 00998-2015UPG
Request Rec'd 09/18/2015
Amended Date
Approval Date 9/21/2015 DS
Permit Expires 3/22/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Speedway, LLC P.O. Box 1500 Springfield, OH 455011500 Contact: Eric M Swaisgood (937) 863-6513</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Speedway #5370 631 North Route 59 Naperville, IL 60540 Contact: Eric M Swaisgood (937) 863-6513</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 8) - 4,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 8) Piping - Flexible Double Wall OPW Flexworks CP-15 non corrosive*
- (d) *Product to be stored in each tank: (TK # 8) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 8) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus in all submersible and dispenser sumps*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) SPECIAL CONTINGENCIES : There are two existing dispenser containment sumps being removed and replaced where a new diesel line is being extended to one of the islands. New islands and dispensers will be installed in their place.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Uni-Pump, Inc.
3070 Helsan Drive

Contact Person: Steve Bennett
Phone: (262) 674-1522

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File