



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7006267
Permit # 01026-2015UPG
Request Rec'd 09/14/2015
Amended Date
Approval Date 9/28/2015 DS
Permit Expires 3/29/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Cheers Food & Fuel, Inc. 5820 Cairo Rd. Paducah, KY 42001</p> <p>Contact: Nathan Long (270) 559-0658</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Cheers Food & Fuel, Inc. 2105 East 5th Street I-24 & Rt. 45 Metropolis, IL 62960</p> <p>Contact: Alisha Richards (270) 443-6076</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 11) - 20,000, (TK # 12) - 5,000, (TK # 13) - 15,000*
 - (b) *Type of tanks:*
 - (c) *Type of piping: (TK # 11, 12, 13) Piping - Flexible Double Wall A.P.T. Poly Tech XP 1500 from existing tanks to new dispensers, (TK # 11, 12, 13) Piping - Shear Valves, (TK # 11, 12, 13) Piping - Valves Ball Valve, (TK # 11, 12, 13) Piping - Dispenser Sumps containment FRP, (TK # 11, 12, 13) Piping - Submersible Sumps containment FRP, (TK # 11, 12, 13) Piping - Sumps Entry Boots, (TK # 11, 12, 13) Piping - Flex Connector Steel*
 - (d) *Product to be stored in each tank: (TK # 11, 12) - Gasoline, (TK # 13) - Diesel Fuel*
 - (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 11, 12, 13) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 in submersible and dispenser sumps*
 - (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) *Spill containment devices, piping, and dispenser containmnt devices:*
 - (h) *Overfill prevention devices:*
 - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) **SPECIAL CONTINGENCIES** : 1) Remove dispensers from Islands. 2) Blow fuel through lines back to tank. 3) Saw cut, bust and remove concrete. 4) Remove old product lines. 5) Bed trnches. 6) Install new Dispenser Sumps and Sub Pump Sumps. 7) Run new product lines. 8) Perform Air test with OSFM. 9) Back fill lines with OSFM approval. 10) Pull new wires in for sump sensors. 11) Pour Concrete and Finish. Mount Sump sensors. 12) Set dispenser back on Island and hook up. 13) Power up dispensers and purge system. 14) Test Sump sensors. 15) Perform final inspection with OSFM. 16) Clean Up job site.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.
2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Contact Person: Billy Thorne
Phone: (573) 335-5529
Contractor Registration # IL1194 Exp. 8/12/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File