



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2022756
Permit # 01045-2015UPG
Request Rec'd 09/29/2015
Amended Date
Approval Date 9/29/2015 DS
Permit Expires 3/29/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C Stores Company 33978 N. US Hwy 45 Gages Lake, IL 600300089</p> <p>Contact: Mike Graham (847) 223-3710 Ext. 15</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Rand Road Shell GCS #192 2113 North Arlington Heights Road Arlington Heights, IL 60004</p> <p>Contact: Vern Gutman (847) 223-3710 Ext. 15</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 7, 8, 9) - 12,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 7, 8, 9) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 7, 8, 9) - Gasoline*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

- Dispenser 3&4-Lower shear valve and re-anchor**
- Dispenser 5&6-Lower shear valve and re-anchor**
- Dispenser 7&8-Lower shear valve and re-anchor**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


DRW Services, Inc.

Contact Person: Douglas Harmon

600 East Joe Orr Road
Chicago Heights, IL 60411

Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File