



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**Amended**

<p><b>FOR OFFICE USE ONLY</b>          Facility # 4038729          Permit # 01013-2015UPG          Request Rec'd 09/23/2015          Amended Date 09/30/2015          Approval Date 9/23/2015 DS          Permit Expires 3/23/2016</p>
--

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity:           United Oil Company          405 South Seminary Road          Downs, IL 61736           Contact: Rocky Bhalla (630) 673-7625</p>	<p>(2) <b>FACILITY</b> - name and address where tanks are located:           Down's Travel Mart          405 South Seminary Road          Downs, IL 61736           Contact: Rocky Bhalla (309) 378-3049</p>
--	--

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 12,000, (TK # 3) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2, 3) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC from tank to first dispenser sump*
- (d) *Product to be stored in each tank: (TK # 2, 3) - Gasoline*
- (e) *Type of leak detection being used:*  
     *Tank:*  
     *Piping: (TK # 2, 3) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 300 in submersible and dispenser sump*
- (f) *Corrosion Protection being used:*  
     *Tank:*  
     *Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

**Installation of new section of pipe from tank sump to first dispenser sump.  
 Installing a new Veeder-Root #794380-208 piping sump sensor in the existing dispenser sump.  
 Existing sensor to remain in the piping sump.**


**Please amend permit to install a new APT line from the premium gas tank piping sump to the first dispenser sump.**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Illinois Oil Marketing Equipment, Inc.  
850 Brenkman Drive  
Pekin, IL 61554

Contact Person: Chris Epkins  
Phone: (309) 347-1819  
Contractor Registration # IL1293 Exp. 2/4/2016

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File