



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 3007214
Permit # 01082-2015UPG
Request Rec'd 10/06/2015
Amended Date
Approval Date 10/6/2015 DS
Permit Expires 4/6/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Sahil Property Holdings, LLC 2102 Broadway Pekin, IL 61554</p> <p>Contact: Lisa Gandhi (630) 795-9258</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Nikli Fuels, Inc. 801 S. 2nd St. Pekin, IL 61554</p> <p>Contact: Janet Holcomb (309) 346-4012</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 5) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 5) Piping - Dispenser Sumps containment FRP*

(d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 5) Leak Detect - Piping - European with No Test Req Suction

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The existing diesel has a 2 product suction pump. The existing pump will be removed, the line from the 10,000 gallon diesel tank will be run to the new island where there will be a (1) product suction pump installed. The existing island will have a (1) product suction pump installed.

Both lines are now european suction and will remain european suction.

Piping will be Ameron 3000 fiberglass single wall pipe.


New island will have a piping sump installed. Existing island will remain as is with no sump. There will be no work done on the existing line.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File