



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2009879
Permit # 00971-2015UPG
Request Rec'd 09/03/2015
Amended Date 10/19/2015
Approval Date 9/14/2015 DS
Permit Expires 3/15/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Krish Ria Convenience, Inc. 1660 W. Main Street St. Charles, IL 60174</p> <p>Contact: Pregnesh Shaw (630) 926-5937</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Krish Ria Convenience, Inc. 1600 W. Main Street St. Charles, IL 60174</p> <p>Contact: Pragnesh Shah (630) 926-5937</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 3, 4) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 3, 4) Piping - Other submersible pump, (TK # 3, 4) Piping - Shear Valves, (TK # 3, 4) Piping - Valves Ball Valve, (TK # 3, 4) Piping - Dispenser Sumps containment FRP, (TK # 3, 4) Piping - Submersible Sumps containment FRP, (TK # 3, 4) Piping - Sumps Entry Boots, (TK # 3, 4) Piping - Flex Connector Steel*

(d) *Product to be stored in each tank: (TK # 3, 4) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 3, 4) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection FE Petro STP-MLD, (TK # 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 Plus

(f) *Corrosion Protection being used:*

Tank:

Piping: (TK # 3, 4) Corrosion Prot - Piping - Fiberglass Non-Corrosive

(g) *Spill containment devices, piping, and dispenser containmnt devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Installing sensors under 4 dispensers and in new tank top sumps. Installing new dispenser containment and new tank sumps. Replacing all piping with double wall Ameron LCX pipe.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Crowne Industries, Ltd.

Contact Person: Robert Sumoski

651 S. Sutton Road #214
Streamwood, IL 60107

Phone: (630) 497-9009
Contractor Registration # IL002345 Exp. 5/16/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File