



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5032563
Permit # 01144-2015UPG
Request Rec'd 10/16/2015
Amended Date
Approval Date 10/19/2015 DS
Permit Expires 4/19/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Casey's Retail Company One Convenience Blvd. P.O. Box 3001 Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238	(2) <u>FACILITY</u> - name and address where tanks are located: Casey's General Stores Inc 115 South Maple Street Brighton, IL 62012 Contact: Jill Reams-Widder (515) 965-6238
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 1, 2) Piping - Shear Valves, (TK # 1, 2) Piping - Valves Ball Valve, (TK # 1, 2) Piping - Dispenser Sumps containment FRP, (TK # 1, 2) Piping - Sumps Entry Boots, (TK # 1, 2) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 1, 2) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 discriminating containment sump*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping: (TK # 1, 2) Corrosion Prot - Piping - Flexible Non-Corrosive*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Pre-manufactured EBW 705 CIGKT Defender spill containment*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : adding two additional 3' x 5' islands with APT poly dispenser containment, OPW 10P-0152 sheer valves , steel flexes, Veeder Root discriminating sump sensors in the new dispenser & existing tank sumps. New APT XP-175SC DW piping to the (2) new islands only

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Seneca Companies, Inc.
4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Contact Person: Keri Hankins
Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File