



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, Illinois 62703-4259
(217)785-1020
Amended

FOR OFFICE USE ONLY

Facility # 4-024060
Permit # 00642-2015UPG
Request Rec'd 07/09/2015
Amended Date 10/22/2015
Approval Date 7/9/2015 DS
Permit Expires 1/11/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) OWNER OF TANKS - Corporation, partnership, or other business entity: Meyer Oil Company 1505 W. Main Street Teutopolis, IL 62467 Contact: Alan Meyer (217) 857-3163	(2) FACILITY - name and address where tanks are located: Mach 1 16719 N. 1000th Street Effingham, Effingham Co., IL Contact: Shannon Cushman (217) 868-2013
---	--

(3) UPGRADE OR REPAIR OF TANKS:


- (a) **Number and size of tanks being upgraded or repaired:** (TK # 4) - 15,000 gallons, (TK # 5) - 6,000 gallons, (TK # 6, 7) - 4,000 gallons
- (b) **Type of tanks:**
- (c) **Type of piping:** (TK # 4, 5, 6, 7) - (Installing) Flex Connector Steel, (TK # 4, 5, 6, 7) - (Installing) Dispenser Sumps containment FRP, (TK # 4, 5, 6, 7) - (Installing) Partial Fiberglass Single Wall Piping to accomodate new dispenser sumps, (TK # 4, 5, 6, 7) - (Installing) Shear Valves
- (d) **Product to be stored in each tank:** (TK # 4, 6, 7) - Gasoline, (TK # 5) - Diesel Fuel
- (e) **Type of leak detection being used:**
 - Tank:**
 - Piping:** (TK # 4) - (Installing) Electronic Pressurized Line Leak Detection Veeder Root TLS 350 , (TK # 5, 6) - (Installing) Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350 (see contingencies)
- (f) **Corrosion Protection being used:**
 - Tank:**
 - Piping:** (TK # 4, 5, 6, 7) - (Installing) Fiberglass Non-Corrosive
- (g) **Spill containment devices, piping, and dispenser containment devices:**
- (h) **Overfill prevention devices:**
- (i) **Manway accessible at grade:**

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES:** Contractor replacing dispensing islands. **In addition to the previously permitted work, the permit was amended to show that the existing DW syphon line that was installed for future use in 2013 will be connected between tanks 5 and 6. Sump sensors will be installed in both sumps and line leak detection for tank #4 is also changing from mechanical to electronic. Product in tank 6 will be changing to Diesel and will be updated in a notification form, per contractor.**

(6) PERSON, FIRM OR COMPANY PERFORMING WORK: UPC Enterprises, LC d/b/a United Petroleum Service 1458 Collins Street St. Louis, MO 63102	Contact Person: Harvey Stokes Phone: (314) 241-3767 Contractor Registration # IL-002402 Exp. 02/10/2016
---	---

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist -
Fire Department -
Division File
(Rev. - 9/10)