



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 3034766
Permit # 01171-2015UPG
Request Rec'd 10/23/2015
Amended Date
Approval Date 10/26/2015 DS
Permit Expires 4/26/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Freedom Oil Company 814 West Chestnut P.O. Box 3697 Bloomington, IL 617023697</p> <p>Contact: Dave Werry (309) 828-7750</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Freedom Oil Company 211 East Peoria Street Goodfield, IL 61742</p> <p>Contact: Dave Werry (309) 828-7750</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 3, 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Raising the shear valves at the diesel dispensers due to OSFM NOV. Site has existing sumps and sump sensors.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>Total Petroleum Service Company 2421 Washington Road Washington, IL 61571</p>	<p>Contact Person: Greg R McCoy Phone: (309) 694-8224 Contractor Registration # IL1079 Exp. 2/8/2016</p>

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File