



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2033538  
Permit # 01178-2015UPG  
Request Rec'd 10/26/2015  
Amended Date  
Approval Date 10/26/2015 DS  
Permit Expires 4/26/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|  |  |
|--|--|
| <p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Exxon Mobil Oil Corporation<br/>3225 Gallows Road<br/>Fairfax, VA 22037</p> <p>Contact: Steve Bunsen (800) 253-8054</p> | <p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Exxon Mobil Joliet Refinery<br/>25915 S Frontage Road<br/>Channahon, IL 60410</p> <p>Contact: Steve Bunsen (815) 423-7655</p> |
|--|--|

(3) **UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000, (TK # 2) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 2) - Gasoline*

(e) *Type of leak detection being used:*

*Tank: (TK # 1, 2) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 with CSLD*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Upgrading ATG to TLS-450 with CSLD

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group  
2422 Center Street  
Rockford, IL 61108

Contact Person: Robert Stenstrom  
Phone: (815) 398-6250  
Contractor Registration # IL1890 Exp. 3/7/2016

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File