



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2010098
Permit # 01179-2015UPG
Request Rec'd 10/23/2015
Amended Date
Approval Date 10/26/2015 DS
Permit Expires 4/26/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Dei Cugini, LLC 6501 W. Roosevelt Rd. Berwyn, IL 60402</p> <p>Contact: Lisa Turano (708) 317-3944</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Harlem Marathon 1427 S. Harlem Ave. Berwyn, IL 60402</p> <p>Contact: Lisa Turano (708) 317-3944</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:


- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 12,000, (TK # 7) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 3, 4, 7) Piping - Fiberglass Single Wall Piping*
- (d) Product to be stored in each tank: (TK # 3, 4) - Gasoline, (TK # 7) - E-85*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : This permit is for the capping off of existing vent pipes that were damaged at facility, and replacing the vents with temporary fiberglass riser pipes at each tank at 12' above grade. Was unable to generate an emergency permit due to the facility being in a out of service status. Please speak to OSFM Fred in regard to this permit and the situation for filing this permit or contact Patrick O'Brien - 847-951-1850 with questions. All tanks emptied of product and tank 3,4 ballasted with 5000 gallons of water on 10/23/15.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
U.S. Venture, Inc. 425 Better Way	Contact Person: Terry Jandrey Phone: (920) 735-8249

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File