



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2010098
Permit # 01015-2015UPG
Request Rec'd 09/23/2015
Amended Date 11/02/2015
Approval Date 9/23/2015 DS
Permit Expires 3/23/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Dei Cugini, LLC 6501 W. Roosevelt Rd. Berwyn, IL 60402 Contact: Lisa Turano (708) 317-3944	(2) <u>FACILITY</u> - name and address where tanks are located: Harlem Marathon 1427 S. Harlem Ave. Berwyn, IL 60402 Contact: Lisa Turano (708) 317-3944
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 3, 4) - 12,000*
 - (b) *Type of tanks:*
 - (c) *Type of piping: (TK # 3, 4) Piping - Fiberglass Single Wall Piping Ameron 4000 L single wall vent, (TK # 3, 4) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 3, 4) Piping - Shear Valves, (TK # 3, 4) Piping - Valves Ball Valve, (TK # 3, 4) Piping - Dispenser Sumps containment FRP, (TK # 3, 4) Piping - Submersible Sumps containment FRP, (TK # 3, 4) Piping - Sumps Entry Boots*
 - (d) *Product to be stored in each tank: (TK # 3, 4) - Gasoline*
 - (e) *Type of leak detection being used:*
 - Tank: (TK # 3, 4) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus ATG, (TK # 3, 4) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus*
 - Piping: (TK # 3, 4) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 3, 4) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus*
 - (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping: (TK # 3, 4) Corrosion Prot - Piping - Flexible Non-Corrosive*
 - (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 3, 4) Spill Contain Device - Pre-manufactured EBW 705 C1GKT Defender spill containment*
 - (h) *Overfill prevention devices: (TK # 3, 4) Overfill Prev Device - Overfill Drop Tube Valve EBW 705, (TK # 3, 4) Overfill Prev Device - Overfill Alarm Veeder Root TLS 450plus*
 - (i) *Manway accessible at grade:*
- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) **SPECIAL CONTINGENCIES :**
- Use (2) 12,000 gallon existing underground storage tanks, (1) 6,000 to be removed


- Installing new product piping, vent piping, and containment sumps
- Installing (2) new 3' x 8' island forms
- Installing new canopy 24' x 53'
- Installing new Veeder Root TLS 450 Plus ATG with probes, overfill alarm, PLLD, tank interstitial sensors, and sump sensors
- Installing new EBW 705 overfills

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

U.S. Venture, Inc.
425 Better Way
Appleton, WI 54915

Contact Person: Terry Jandrey
Phone: (920) 735-8249
Contractor Registration # IL002403 Exp. 3/12/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File