



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 2007605  
Permit # 01141-2015UPG  
Request Rec'd 10/19/2015  
Amended Date 11/02/2015  
Approval Date 10/19/2015 DS  
Permit Expires 4/19/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Fred's Winnetka Service, Inc. 574 Green Bay Rd. Winnetka, IL 60093</p> <p>Contact: Dorothy Majewski (847) 446-3025</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Fred's Winnetka Service, Inc. 574 Greenbay Rd. Winnetka, IL 60093</p> <p>Contact: Dorothy Majewski (847) 446-3025</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 1, 2) - Gasoline*

(e) *Type of leak detection being used:*

*Tank: (TK # 1, 2) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD*

*Piping: (TK # 1, 2) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FX1*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Manhole Pre-manufactured OPW 1-2100C DEVR spill containment manhole*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replacing the existing OPW tank monitoring system with Veeder Root TLS 350 (w/ CSLD), the existing Red Jacket Pro Link line leak detection with Red Jacket FX1 mechanical line leak detection, and repalcement of the existing RUL spill manhole (5-gallon) with OPW 1C-2100 DEVR spill manhole. **AMENDMENT 11/02/15 - Raising existing impact valves to proper height inside the existing dispenser pans (per NOV).**

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


Performance Tank, Inc.

Contact Person: Tim Berg

730 Creel Drive  
Wood Dale, IL 60191

Phone: (630) 860-9500  
Contractor Registration # IL881 Exp. 10/27/2016

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File