



Office of the Illinois State Fire Marshal  
 Division of Petroleum and Chemical Safety  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 2177851020

**FOR OFFICE USE ONLY**  
 Facility # 2016434  
 Permit # 01233-2015CAT  
 Request Rec'd 11/04/2015  
 Amended Date  
 Approval Date 11/4/2015 DS  
 Permit Expires 5/4/2016

**Permit for INSTALLATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. A required job schedule for cathodic protection upgrade of underground storage tank(s) and piping must be submitted to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>D &amp; R Enterprises, LLC        535 East North Street, Suite C        Bradley, IL 60915</p> <p>Contact: Perry Denault (815) 929-9539</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>#15 T D Pete's Manteno        244 N Locust St        Manteno, IL 60950</p> <p>Contact: Jeanne Gotkowski (815) 468-8751</p>
--	--

**(3) UPGRADE, OR REPAIR OF CATHODIC PROTECTION SYSTEM:**

*(a) Number and size of tanks having cathodic protection installed, upgraded, or repaired: (TK # 1) - 10,000*

*(b) Type of tanks:*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 1) - Gasoline*

*(e) Type of leak detection being used:*

*Tank:*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping: (TK # 1) Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection*

*(g) NACE certified designer:*

*(h) Method of integrity assessment of tank(s) being used:*

**(4)** The owner must notify this Office when completion of cathodic protection upgrade has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for cathodic protection upgrade to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling 2177851020.

**(5) SPECIAL CONTINGENCIES :** Installing sacrificial anodes to submersible pump flexes on tank #1

**(6)** The owner must notify this Office when completion of tank abandonment has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

<p><b>(7) PERSON, FIRM OR COMPANY PERFORMING WORK:</b></p>	
<p>Midwest Petroleum Service, LLC        23535 North 1530 East Road        Danville, IL 61834</p>	<p>Contact Person: Mike Hall        Phone: (217) 443-2263        Contractor Registration # IL002306 Exp. 6/26/2016</p>

---

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File