



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 2043486 Permit # 01239-2015UPG Request Rec'd 11/05/2015 Amended Date Approval Date 11/5/2015 DS Permit Expires 5/5/2016</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Aurora Tech Holdings, LLC 1800 Tyhson's Blvd. #350 McLean, VA 22102 Contact: Michael Clemson (703) 565-2102</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Aurora Tech Holdings, LLC 4267 Meridian Parkway Aurora, IL 60504 Contact: George Anderson (703) 565-2102</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 15,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 1, 2) - Diesel Fuel*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 1, 2) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 Plus, (TK # 1, 2) Leak Detect - Piping - Pressurized Line Leak Detection
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

- 1. Permit with State Fire Marshall's office to replace the existing Veeder Root TLS 300C with a new Veeder Root TLS 350 plus and install PLLD line leak detection with alarm only capability for backup generator operation.**
- 2. Remove old mechanical line leak detectors with new PLLD line leak detectors into existing Red Jacket submersible pumps.**
- 3. Pull new Beldon wire to new PLLD line leak detectors.**


4. Remove existing Veeder Root TLS 300C and install new Veeder Root TLS 350 plus console.
5. Wire and program new Veeder Root TLS 350 console.
6. Test all sensors, probes and new PLLD line leak detectors.(PLLD to alarm only and not shut down fuel flow for generator day tanks)
7. Schedule and conduct final inspection with State Fire Marshall

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

J & D Mechanical Industries, Inc.
6521 Main Street, Suite A P.O. Box 113
Union, IL 60180

Contact Person: Cheryl Zielke
Phone: (815) 923-4510
Contractor Registration # IL1943 Exp. 4/26/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File