



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

|                            |
|----------------------------|
| <b>FOR OFFICE USE ONLY</b> |
| Facility # 2014601         |
| Permit # 01253-2015UPG     |
| Request Rec'd 11/09/2015   |
| Amended Date               |
| Approval Date 11/9/2015 DS |
| Permit Expires 5/10/2016   |

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

|  |   |
|--|---|
| <p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Speedway, LLC<br/>P.O. Box 1500<br/>Springfield, OH 455011500</p> <p>Contact: Eric M. Swaisgood (937) 863-6513</p> | <p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Speedway #7756<br/>1156 Dundee Avenue<br/>Elgin, IL 60120</p> <p>Contact: Eric Swaisgood (937) 863-6513</p> |
|--|---|

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 15,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Other submersible pump, (TK # 4) Piping - Valves Ball Valve, (TK # 4) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 4) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

We will be removing (2) existing submerge pumping units that are located inside of the one sump. Both are not working and that is reason for this upgrade permit. We will be installing only 1 new FE Petro 2 HP submerge pumping unit and repipe inside the sump only from teh fiberglass product line male adapter and install new 2" SS flex connector, ball valve and related steel fittings

No other work outside of the sump will be done

Location currently has a Veeder Root PLLD line leak detector which we will install on new submerge pumping unit.


No product release was detected

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.  
600 East Joe Orr Road  
Chicago Heights, IL 60411

Contact Person: Douglas Harmon  
Phone: (708) 758-3222  
Contractor Registration # IL194 Exp. 3/10/2016

Sincerely,

  
\_\_\_\_\_

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File