



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 7020851
Permit # 01300-2015UPG
Request Rec'd 11/19/2015
Amended Date
Approval Date 11/23/2015 DS
Permit Expires 5/24/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Russell Oil Company 200 E. Main P.O. Box 73 Galatia, IL 62935 Contact: Terry Stevens (618) 268-4722	(2) <u>FACILITY</u> - name and address where tanks are located: Russell Oil Co. 303 E. Poplar Harrisburg IL 62946 Contact: Parys Wilkins (618) 268-4722
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 11,000, (TK # 6) - 4,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5, 6) Piping - Flexible Double Wall A.P.T. Poly Tech S150SC, (TK # 5, 6) Piping - Transition Sumps FRP fiberglass*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline, (TK # 6) - E-85*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 5, 6) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


- (5) SPECIAL CONTINGENCIES** : Transition sump will be APT Model # IPS-24-24 Manhole Pemco 105 24 X 24 Veeder Root Sump sensors 794380-208 existing piping to E-85 and Unlead will have 2 feet of line cut and reattached inside the transition sump.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.
2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Contact Person: Billy Thorne
Phone: (573) 335-5529
Contractor Registration # IL1194 Exp. 8/12/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File