



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 6003275 Permit # 01304-2015UPG Request Rec'd 11/18/2015 Amended Date Approval Date 11/23/2015 DS Permit Expires 5/24/2016</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>St. Elizabeth Hospital 211 S. 3rd Street Belleville, IL 62222</p> <p>Contact: Michael Bold (618) 234-2120</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>St. Elizabeth Hospital 211 S. 3rd Street Belleville, IL 62222</p> <p>Contact: Michael Bold (618) 234-2120</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 4) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 4) Piping - Flexible Single Wall Piping, (TK # 4) Piping - Steel Single Wall Piping, (TK # 4) Piping - Flexible Double Wall OPW Flexworks CP-15 non corrosive, (TK # 4) Piping - Flexible Double Wall OPW Pisces, (TK # 4) Piping - Valves Ball Valve*
- (d) Product to be stored in each tank: (TK # 4) - Diesel Fuel*
- (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Saw cut and remove concrete from tank to building exterior wall. Install new OPW flex pipe inside of chase pipe from tank to building, install sono tube around location of tank access. Install transition assembly to turn piping up and install steel piping out of ground to penetrate into building and tie into existing steel pipe inside of the building. Used OPW DEB-4175 to prevent water accessing chase pipe.

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Neumayer Equipment Company, Inc.</p>	<p>Contact Person: Kerri McKay</p>
--	------------------------------------

5060 Arsenal Street
Saint Louis, MO 63139

Phone: (314) 932-3783
Contractor Registration # IL1502 Exp. 3/26/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File