



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 6039511
Permit # 01210-2015UPG
Request Rec'd 10/29/2015
Amended Date 12/07/2015
Approval Date 10/29/2015 DS
Permit Expires 4/29/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company One Convenience Blvd. P.O. Box 3001 Ankeny, IA 50021</p> <p>Contact: Jill Reams-Widder (515) 965-6238</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Casey's General Store #2321 710 West Broadway Street Sparta, IL 62286</p> <p>Contact: Nick Murray (515) 965-6238</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 12,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 1, 2) Piping - Dispenser Sumps containment FRP*

(d) *Product to be stored in each tank: (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350 PLLD leak sensors

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :


The existing piping is Ameron pipe. We are installing APT 175 SC pipe to the (2) new islands. Existing (4) islands and canopy to remain. Adding (2) additional dispensers with dispenser sumps and piping sump sensors and extending canopy. We will install a piping sump sensor in the existing dispenser sump where the connection is made for the new piping. Piping to be APT 175 SC

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File