



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1003663
Permit # 01344-2015UPG
Request Rec'd 12/03/2015
Amended Date
Approval Date 12/7/2015 DS
Permit Expires 6/7/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Mid American Oil Company 2590 Biltmore Circle Aurora, IL 60503 Contact: Baljit Sidhu (630) 682-0941	(2) <u>FACILITY</u> - name and address where tanks are located: Princeton Fast Stop 720 N. Main St. Princeton, IL 61356 Contact: Jennifer Welsh (815) 872-0706
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 9, 10, 12) - 10,000, (TK # 11) - 6,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 9, 10, 11, 12) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 9, 10, 11, 12) Piping - Dispenser Sumps containment FRP, (TK # 9, 10, 11, 12) Piping - Submersible Sumps containment FRP*
- (d) *Product to be stored in each tank: (TK # 9, 10, 11) - Gasoline, (TK # 12) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 9, 10, 11, 12) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : All new, piping to three new gas island with new dispenser sumps and one new diesel island with new dispenser sump. Also includes new sub pump sumps. All sumps with sensors.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illowa Enterprises, Inc.
2703 4th Avenue
Moline, IL 61265

Contact Person: Rob Vynck
Phone: (309) 762-1729
Contractor Registration # IL981 Exp. 5/1/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File