



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 6046048  
Permit # 01360-2015REM  
Request Rec'd 12/08/2015  
Amended Date  
Approval Date 12/8/2015 SB  
Permit Expires 6/8/2016

**Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.**

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>StoneMor Partners, L.P. 311 Veterans Highway, Suite B Levittown, PA 19056  Contact: (215) 826-2828</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Sunset Hill Cemetery 50 Fountain Drive Glen Carbon, IL 62034  Contact: (215) 826-2828</p>
---	--

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1) - 500*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number:*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

Chase Environmental Group Inc  
11450 Watterson Court  
Louisville, KY 40299

Contact Person: Mary Anne Lewis  
Phone: (502) 267-1455  
Contractor Registration # IL2036 Exp. 3/16/2017

Sincerely,

Shelly Bradley

cc: Storage Tank Safety Specialist  
Division File