



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 4014330
Permit # 01172-2015UPG
Request Rec'd 10/23/2015
Amended Date 12/08/2015
Approval Date 10/26/2015 DS
Permit Expires 4/26/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: TA Operating LLC 24601 Center Ridge Road, Suite 200 d/b/a Travel Centers of America, Inc. Westlake, OH 44145 Contact: Katie Wells (216) 870-4916	(2) <u>FACILITY</u> - name and address where tanks are located: Gilman Minit Mart #625 1401 Hwy 24 West Road Gilman, IL 609386053 Contact: (815) 237-0100 Ext. 221
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 7) - 5,000, (TK # 8, 9) - 15,000, (TK # 10) - 12,000, (TK # 11) - 8,000*

(b) *Type of tanks:*

(c) *Type of piping:*

(d) *Product to be stored in each tank: (TK # 7, 10, 11) - Gasoline, (TK # 8, 9) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank: (TK # 7, 8, 9, 10, 11) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 450 Plus ATG

Piping: (TK # 7, 10, 11) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 450 Plus, (TK # 7, 8, 9, 10, 11) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 450 Plus, (TK # 8, 9) Leak Detect - Piping - Mechanical Pressurized Line Leak Detection Red Jacket FXIDV

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Could not move cable through conduits for tank ID 8 and 9. Facility owner has opted not to install Veeder Root PLID electronic line leak detectors for Red Jacket mechanical line leak detectors and annual testing.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Total Petroleum Service Company

Contact Person: Greg R McCoy

2421 Washington Road
Washington, IL 61571

Phone: (309) 694-8224
Contractor Registration # IL1079 Exp. 2/8/2016

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File