



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 5008286  
Permit # 01372-2015UPG  
Request Rec'd 12/10/2015  
Amended Date  
Approval Date 12/10/2015 DS  
Permit Expires 6/10/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>St. John's Hospital 800 E. Carpenter Street Springfield, IL 62769</p> <p>Contact: Greg Stading (217) 544-6464 Ext. 44595</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>St. John's Hospital 800 E. Carpenter Springfield, IL 62701</p> <p>Contact: Tim Ferguson (217) 544-6464</p>
---	---

(3) **UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2) Piping - Steel Single Wall Piping , (TK # 1, 2) Piping - Valves Ball Valve*
- (d) *Product to be stored in each tank: (TK # 1, 2) - Heating Oil*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : Replacing (2) manholes and piping Installing (4) new ball valves for testing lines.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

W J Scott Company  
3861 Tozer Road  
Springfield, IL 62707

Contact Person: James Scott  
Phone: (217) 787-6081  
Contractor Registration # IL1949 Exp. 4/18/2016

Sincerely,

*Daniel G. Starks*

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File