



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2021504
Permit # 00993-2015UPG
Request Rec'd 09/17/2015
Amended Date 12/15/2015
Approval Date 9/17/2015 DS
Permit Expires 3/17/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Fire King Oil Company 1901 Elston Chicago, IL 60622</p> <p>Contact: Irv Walzer (312) 772-4095</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Fire King Mobil 1101 Waukegan Road Northbrook, IL 60062</p> <p>Contact: Athar Mughal (312) 772-4095</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 8,000, (TK # 2) - 6,000, (TK # 3) - 4,000, (TK # 4) - 12,000, (TK # 5) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3, 4, 5) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 1, 2, 3, 4, 5) Piping - Dispenser Sumps containment FRP*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3, 4) - Gasoline, (TK # 5) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Please ammend to show that we installed containment under dispensers 5/6, 7/8 and 13/14. The inspector looked at this when he did his inspection. The permit application originally showed that we were only installing it under 7/8 but they are on the same island.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Anderson Pump Service, Inc.

Contact Person: Rick Krol

19659 South 97th Avenue
Mokena, IL 60448

Phone: (708) 478-6190
Contractor Registration # IL002275 Exp. 5/21/2016

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File