



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 6008323
Permit # 01398-2015UPG
Request Rec'd 12/15/2015
Amended Date
Approval Date 12/15/2015 DS
Permit Expires 6/15/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Parsons Oil Co., LLC P.O. Box 100 West Alton, MO 63386 Contact: Tom Parsons (618) 580-7269</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Parsons Oil Co., LLC 4200 College Avenue Alton, IL 62002 Contact: Tom Parson (618) 580-7269</p>
--	---

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) Number and size of tanks being upgraded or repaired: (TK # 13) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 13) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 13) Piping - Shear Valves, (TK # 13) Piping - Dispenser Sumps containment FRP, (TK # 13) Piping - Sumps Entry Boots, (TK # 13) Piping - Flex Connector Steel*
- (d) Product to be stored in each tank: (TK # 13) - Diesel Fuel*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Remove dispenser from island and saw cut and remove concrete from top of one diesel island and next to island to be able to cut back product pipe and conduit to install new dispenser sump. Run new product pipe and conduit into sump using entry boots, install new flex connector and shear valve below dispenser and reinstall the dispenser.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Neumayer Equipment Company, Inc. 5060 Arsenal Street	Contact Person: Kerri McKay Phone: (314) 932-3783

Sincerely,

  
\_\_\_\_\_

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File