



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**Amended**

**FOR OFFICE USE ONLY**

Facility # 3029405  
Permit # 01196-2015UPG  
Request Rec'd 10/27/2015  
Amended Date 12/21/2015  
Approval Date 10/28/2015 DS  
Permit Expires 4/28/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company One Convenience Blvd. P.O. Box 3001 Ankeny, IA 50021</p> <p>Contact: Jill Reams-Widder (515) 965-6238</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Casey's General Store South West Corner Route 22 and Maple Avenue Minier, IL 61759</p> <p>Contact: Marcie Jenkins (515) 965-6238</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Dispenser Sumps containment FRP, (TK # 1, 2, 3) Piping - Sumps Entry Boots, (TK # 1, 2, 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping: (TK # 1, 2, 3) Corrosion Prot - Piping - Fiberglass Non-Corrosive*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2, 3) Spill Contain Device - Pre-manufactured EBW 705 CIGKT Defender spill containment*
- (h) *Overfill prevention devices: (TK # 1, 2, 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

not installing Veeder Root sump sensors ,Customer ask not to install sump sensors if not required.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**


Seneca Companies, Inc.

Contact Person: Keri Hankins

4140 East 14th Street PO Box 3360  
Des Moines, IA 50313

Phone: (816) 761-1270  
Contractor Registration # IL598 Exp. 2/23/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File