



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2029288
Permit # 01418-2015UPG
Request Rec'd 12/21/2015
Amended Date
Approval Date 12/21/2015 DS
Permit Expires 1/2/2016

**Permit for Emergency Repair Request on 12/16/2015**

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Ahmad Zahdan-Five M Oil, Inc. 10017 S. Menard Ave. Oak Lawn, IL 60453</p> <p>Contact: Ahmad Zahdan (708) 372-7632</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Pal Mart, Inc. 415 New Avenue Romeoville, IL 60441</p> <p>Contact: Jibby Thomas (708) 253-9293</p>
---	--

**(3) UPGRADE OR REPAIR OF TANKS:**


- (a) Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 2) Piping - Fiberglass Single Wall Piping Ameron*
- (d) Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : This permit application is for the emergency repair previously requested. Repairing hole in 2" fiberglass pipe under dispenser 5/6.

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Ombliis, Inc. 24325 Leski Lane Plainfield, IL 60585</p>	<p>Contact Person: Kiran Madhu Phone: (630) 649-8699 Contractor Registration # IL002410 Exp. 8/10/2017</p>

Sincerely,



---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File