



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 1015875
Permit # 01425-2015UPG
Request Rec'd 12/22/2015
Amended Date
Approval Date 12/22/2015 DS
Permit Expires 1/5/2016

Permit for Emergency Repair Request on 12/21/2015

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Harlem Consolidated School District 122 P O Box 2021 Loves Park, IL 611300021 Contact: Wayde Mitchell (815) 654-4633	(2) <u>FACILITY</u> - name and address where tanks are located: Harlem Transportation Garage 880 Roosevelt Road Machesney Park, IL 61115 Contact: Wayde Mitchell (815) 654-4633
---	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 4) - 2,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 4) Piping - Galvanized Steel Single Wall Piping*

(d) *Product to be stored in each tank: (TK # 4) - Diesel Fuel*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Replaced Damaged Total Containment single wall flex piping with 2" rigid galvanized, air tested at 20# for 1 hour and piping held. Replaced approximately 5' at riser vent pipe end of piping.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Howard Lee & Sons Inc
4093 Perryville Road PO Box 446
Cherry Valley, IL 61016

Contact Person: Mike Lee
Phone: (815) 332-4966
Contractor Registration # IL456 Exp. 3/20/2016

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File