



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 5027339 Permit # 00014-2016UPG Request Rec'd 01/04/2016 Amended Date Approval Date 1/4/2016 DS Permit Expires 7/6/2016</p>

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Casey's Retail Company One Convenience Blvd. P.O. Box 3001 Ankeny, IA 50021 Contact: Jill Reams-Widder (515) 965-6238</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Casey's General Store #2577 110 Springfield Street Kincaid, IL 62540 Contact: Jill Reams-Widder (515) 965-6238</p>
--	---


- (3) UPGRADE OR REPAIR OF TANKS:**
- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 12,000, (TK # 2) - 6,000*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 1, 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 1, 2) Piping - Submersible Sumps containment FRP*
 - (d) Product to be stored in each tank: (TK # 1) - Gasoline, (TK # 2) - Diesel Fuel*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Pre-manufactured EBW 705 CIGKT Defender spill containment*
 - (h) Overfill prevention devices: (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube, (TK # 1, 2) Overfill Prev Device - Overfill Drop Tube Valve EBW 708 Auto Limiter II*
 - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES :** Installing New Franklin Fueling TMA-4236 fiberglass tank sumps with partial Ameron 3000L Double wall fiberglass piping into the new sumps. Installing New 5 gallon EBW 705 series Defender spill containment with EBW 70849302 CoAxle overfill drop tube in the Gas tank & OPW 71SO-410C straight Overfill in the Diesel

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Seneca Companies, Inc.</p>	<p>Contact Person: Keri Hankins</p>
--	-------------------------------------

4140 East 14th Street PO Box 3360
Des Moines, IA 50313

Phone: (816) 761-1270
Contractor Registration # IL598 Exp. 2/23/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File