



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2023126
Permit # 00037-2016UPG
Request Rec'd 01/08/2016
Amended Date
Approval Date 1/11/2016 DS
Permit Expires 7/12/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Graham Enterprise, Inc. 446 Morris Ave. P.O. Box 777 Mundelein, IL 600601919</p> <p>Contact: Henry Dudzie (847) 837-0777</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Park Ridge BP (GEI-183) 1220 West Touhy Avenue Park Ridge, IL 60068</p> <p>Contact: Kris Bernatek (847) 837-0785</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 4,000, (TK # 3) - 6,000, (TK # 4) - 8,000, (TK # 5) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2, 3, 4, 5) Piping - Other submersible pump, (TK # 2, 3, 4, 5) Piping - Valves Ball Valve, (TK # 3, 5) Piping - Fiberglass Single Wall Piping A.O. Smith, (TK # 3, 4, 5) Piping - Submersible Sumps Bravo B-400 Series, (TK # 4) Piping - Submersible Sumps containment FRP*
- (d) *Product to be stored in each tank: (TK # 2, 3, 4, 5) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection continuous line pressure monitor*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

PNL AND TWO RUL TANKS TO INSTALL BRAVO FIBERGLASS CONTAINMENT SUMPS AND NEW FE PETRO SUBMERSIBLE MOTORS.

RUL-4,000-GALLON TANKS HAS AN EXISTING ENVIRON POLY SUMP TO REMAIN, ADD NEW FE PETRO SUBMERSIBLE MOTOR.


PNL TANK HAS EXISTING VEEDER ROOT WPLLD, UPGRADE TO PLLD HARD WIRED TO EXISTING TLS-350.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Douglas Harmon
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File