



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

<p>FOR OFFICE USE ONLY</p> <p>Facility # 2001228 Permit # 00052-2016UPG Request Rec'd 01/05/2016 Amended Date Approval Date 1/13/2016 Permit Expires 7/13/2016</p>
--

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Chicago Title Land Trust Co. A/T/U #8002361782 10 S. La Salle, Suite 2750 Chicago, IL 60603</p> <p>Contact: John Jansen (773) 229-0670</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>First Transit 615 West 41st Street Chicago, IL 60608</p> <p>Contact: John Jansen (773) 890-4675</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 5) Piping - Fiberglass Double Wall A.O. Smith, (TK # 5) Piping - Extractor Fitting Valves, (TK # 5) Piping - Shear Valves, (TK # 5) Piping - Valves Ball Valve, (TK # 5) Piping - Submersible Sumps containment FRP, (TK # 5) Piping - Dispenser Sumps Bravo B-1000 Series*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root Pressurized, (TK # 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

<p>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</p> <p>Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road</p>	<p>Contact Person: Larry Cherner Phone: (847) 465-4000</p>
--	---

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File