



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 4006092
Permit # 00082-2016UPG
Request Rec'd 01/26/2016
Amended Date
Approval Date 1/26/2016 DS
Permit Expires 7/26/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC P.O. Box 347 Columbus, IN 472020347  Contact: Matthew Jordan (812) 379-9227</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Circle K #1226 1301 South Mattis Avenue Champaign, IL 61820  Contact: Keri Hogue (630) 942-5363</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

*(a) Number and size of tanks being upgraded or repaired: (TK # 1, 2) - 10,000, (TK # 3) - 6,000*

*(b) Type of tanks: (TK # 1, 2, 3) Tank - Stand Alone System*

*(c) Type of piping:*

*(d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*

*(e) Type of leak detection being used:*

*Tank: (TK # 1, 2, 3) Leak Detect - Tank - Interstitial Monitoring Veeder Root TLS 450 Plus*

*Piping:*

*(f) Corrosion Protection being used:*

*Tank:*

*Piping:*

*(g) Spill containment devices, piping, and dispenser containment devices:*

*(h) Overfill prevention devices:*

*(i) Manway accessible at grade:*

**(4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES : Installation of the stand alone system**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
<p>Tank Tech, Inc. 3975 State Highway H Sikeston, MO 63801</p>	<p>Contact Person: Jonathan McNeely Phone: (573) 471-1932 Contractor Registration # IL2136 Exp. 1/14/2018</p>

Sincerely,

*Daniel G. Starks*

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File