



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
3127453152

Amended

FOR OFFICE USE ONLY

Facility # 2000391
Permit # 01430-2015REM
Request Rec'd 12/29/2015
Amended Date 01/27/2016
Approval Date 12/29/2015
Permit Expires 6/29/2016

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>City of Chicago 30 North LaSalle, Suite 400 Department Of Transportation Bureau Of Highway Chicago, IL 60602 Contact: Bridget Stalla (312) 742-1259</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>City of Chicago former Vienna Sausage Mfg/ Peer Cartage 2501 N. Damen Ave. Chicago, IL 60647 Contact: Bridget Stalla (312) 742-1259</p>
--	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 5) - 2,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 5) - Heating Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 5) - 12/31/1973*

- (4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**


Change tank Id to #5

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

K-Plus Mechanical, Inc.
329 W. 18th St., Ste. 614
Chicago, IL 60616

Contact Person: Gerald Ford
Phone: (815) 230-3040
Contractor Registration # IL002335 Exp. 2/9/2016

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File

