



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2034032
Permit # 00089-2016UPG
Request Rec'd 01/27/2016
Amended Date
Approval Date 1/27/2016 DS
Permit Expires 7/27/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>DRD Investments, Inc. 7211 S. Lockwood Bedford Park, IL 60638</p> <p>Contact: Donald Burns (708) 878-3700</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>GDS 7211 S. Lockwood Bedford Park, IL 60638</p> <p>Contact: Donald Burns (708) 878-3700</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 2,500, (TK # 2) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 2) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 1, 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 1, 2) Piping - Valves none check valve, (TK # 1, 2) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series*

(d) *Product to be stored in each tank: (TK # 1) - Diesel Fuel, (TK # 2) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping: (TK # 1, 2) Leak Detect - Piping - European with No Test Req Suction

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 1, 2) Spill Contain Device - Manhole Pre-manufactured EBW 705*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

INSTALLING NEW AMERON LCX EUROPEAN SAFE SUCTION PIPING ON 2 EXISTING UST'S, INSTALLING ONE NEW APT DISPENSER

BOX, ONE NEW DUAL HOSE, DUAL PRODUCT SUCTION PUMP, NEW EBW 705 SPILL CONTAINMENTS, NEW ISLAND FORM, INSTALLING


NEWSINGLE WALL AMERON VENT LINES

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Petroleum Technologies Equipment, Inc.
8447 West 44th Place
Lyons, IL 60534

Contact Person: Thomas J JR Doherty
Phone: (708) 426-0400
Contractor Registration # IL2051 Exp. 1/17/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File