



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 4037346
Permit # 00099-2016UPG
Request Rec'd 01/21/2016
Amended Date
Approval Date 2/1/2016 DS
Permit Expires 8/2/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Bhalla Enterprises, Inc. P.O. Box 1263 Bloomington, IL 61702</p> <p>Contact: Karen Anderson (630) 673-7625</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Towanda Fast Stop 204 N. Jefferson Street Towanda, IL 61776</p> <p>Contact: Bonnie Smith (630) 673-7625</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 1) - 10,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1) Piping - Flexible Double Wall A.P.T. Poly Tech S175SC, (TK # 1) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series*
- (d) Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 1) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Incon TSP ULS
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

The scope of work consists of the installation of a new dispenser island for a diesel master satellite dispenser. The diesel supply piping for the new island will come from the north island. there will also be a new line installed for the satellite side of the new dispenser.


The piping will be APT-175SC double wall flexible pipe. There will be Incon #TSP-ULS piping sump sensors installed in the existing north dispenser box and the proposed new dispenser box in the new island.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Illinois Oil Marketing Equipment, Inc.
850 Brenkman Drive
Pekin, IL 61554

Contact Person: Chris Epkins
Phone: (309) 347-1819
Contractor Registration # IL1293 Exp. 2/4/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File