



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

<b>FOR OFFICE USE ONLY</b>
Facility # 2011793
Permit # 00116-2016UPG
Request Rec'd 02/03/2016
Amended Date
Approval Date 2/3/2016 DS
Permit Expires 8/3/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p><b>(1) OWNER OF TANKS</b> - Corporation, partnership, or other business entity:</p> <p>Krishma Enterprises, Inc. 314 South Lewis Avenue Waukegan, IL 60085</p> <p>Contact: Dave Dilip (847) 293-2514</p>	<p><b>(2) FACILITY</b> - name and address where tanks are located:</p> <p>Rashmi Quick Mart &amp; Beer (Marathon) 314 South Lewis Avenue Waukegan, IL 60085</p> <p>Contact: Dale Houston (847) 293-2514</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 6,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 1, 2, 3) Piping - Flexible Double Wall OPW Pisces, (TK # 1, 2, 3) Piping - Shear Valves*
- (d) Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) Type of leak detection being used:*  
*Tank:*  
*Piping: (TK # 1, 2, 3) Leak Detect - Piping - Stand Alone Sensor Interstitial Monitoring Franklin Fueling Systems DC 404 stand alone sump sensor*
- (f) Corrosion Protection being used:*  
*Tank:*  
*Piping:*
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


**(5) SPECIAL CONTINGENCIES : NOTE: Contractor indicates that there are existing dispenser and submersible sumps, but if there are not sumps existing they MUST be installed. Piping will be pulled through existing chase piping from existing tanks to existing dispensers. Sumps sensors must be installed at ALL submersible and dispenser sumps.**

<b>(6) PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Interstate Pump & Tank, Inc.	Contact Person: Dan McMahon

901 Niagara Street  
Waukesha, WI 53186

Phone: (262) 524-8494  
Contractor Registration # IL1171 Exp. 5/7/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in black ink and is positioned above a thin horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist  
Division File