



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2043456  
Permit # 00139-2016UPG  
Request Rec'd 02/08/2016  
Amended Date  
Approval Date 2/8/2016 DS  
Permit Expires 8/9/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Arkayen, Inc. 3646 Pebblebeach Rd. Northbrook, IL 60062</p> <p>Contact: Hemant Shah (773) 895-0069</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Citgo Gas Station 8575 W. Dempster Niles, IL 60648</p> <p>Contact: Mike Patel (773) 895-0069</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

(a) *Number and size of tanks being upgraded or repaired: (TK # 1) - 20,000, (TK # 5, 7) - 6,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 1, 5, 7) Piping - Shear Valves*

(d) *Product to be stored in each tank: (TK # 1, 5, 7) - Gasoline*

(e) *Type of leak detection being used:*

*Tank:*

*Piping:*

(f) *Corrosion Protection being used:*

*Tank:*

*Piping:*

(g) *Spill containment devices, piping, and dispenser containment devices:*

(h) *Overfill prevention devices:*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Break piping under 2- dispensers to lower existing shear valves. Using existing shaer valves, just lowering piping then re installing shaer valves. A third party precision test will be performed prior to opening lines for service. All piping is in containment.

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Ampsco Service Corp  
730 Creel Dr.  
Wood Dale, IL 60191

Contact Person: Chris Derro  
Phone: (708) 795-9052  
Contractor Registration # IL002399 Exp. 12/20/2017

Sincerely,

---

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File