



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2014560
Permit # 00193-2016REM
Request Rec'd 02/22/2016
Amended Date
Approval Date 2/22/2016 DS
Permit Expires 8/23/2016

Permit for REMOVAL of Underground Storage Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>BAPA, LLC & PT, LLC 31366 N. Hwy. 45 Libertyville, IL 60048 Contact: Bruce Hill (847) 680-5831</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>State Oil Company #290 d/b/a Palos Hills Marathon 11056 Southwest Hwy. Palos Hills, IL 60464 Contact: Schumann R G (708) 335-0600</p>
--	---

(3) **REMOVAL OF PIPING:**

- (a) *Description/location of piping being removed:*
- (b) *Which tank(s) are associated with the piping being removed: (TK # 1, 2, 3) - 8,000*
- (c) *Reason of piping being removed:*
- (d) *If piping is leaking, indicate IEMA incident number: 1993-1121*

- (4) After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES :**

WE WILL BE REMOVING ALL EXISTING PRODUCT PIPING, DISPENSER PANS AND SUBMERGE PUMP CONTAINMENT SUMPS.

ALL EXISTING VENT PIPING WILL REMIAN

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Douglas Harmon
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2016

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File