



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2014560
Permit # 00194-2016UPG
Request Rec'd 02/22/2016
Amended Date
Approval Date 2/23/2016 DS
Permit Expires 8/23/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>BAPA, LLC & PT, LLC 31366 N. Hwy. 45 Libertyville, IL 60048</p> <p>Contact: Bruce Hill (847) 680-5831</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>State Oil Company #290 d/b/a Palos Hills Marathon 11056 Southwest Hwy. Palos Hills, IL 60464</p> <p>Contact: Schumann R G (708) 335-0600</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 1, 2, 3) - 8,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 1, 2, 3) Piping - Fiberglass Double Wall NOV Fiberglass Systems Red Thread IIA fiberglass piping, (TK # 1, 2, 3) Piping - Shear Valves, (TK # 1, 2, 3) Piping - Valves Ball Valve, (TK # 1, 2, 3) Piping - Dispenser Sumps Bravo B-7000 Series, (TK # 1, 2, 3) Piping - Submersible Sumps Bravo B-400 Series, (TK # 1, 2, 3) Piping - Flex Connector Steel*
- (d) *Product to be stored in each tank: (TK # 1, 2, 3) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank: (TK # 1, 2, 3) Leak Detect - Tank - Non-Discriminating Sensors Interstitial Monitoring Veeder Root TLS 350 micro sensor*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

We will be removing existing submerge pump sumps and replace with new Bravo Fiberglass sumps B-400.

Remove old dispenser pans and install new Bravo B7000 fiberglass dispensers sumps with new OPW 10BFP-5725 shear valves

Repipe all product with new NOV 3" over 2" fiberglass doublewall piping


Upgrade existing Veeder Root TLS-350 by adding sump non discriminating sump sensors.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

DRW Services, Inc.
600 East Joe Orr Road
Chicago Heights, IL 60411

Contact Person: Douglas Harmon
Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2016

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File