



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

Amended

FOR OFFICE USE ONLY

Facility # 2023126
Permit # 00037-2016UPG
Request Rec'd 01/08/2016
Amended Date 03/02/2016
Approval Date 1/11/2016 DS
Permit Expires 7/12/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Graham Enterprise, Inc. 446 Morris Ave. P.O. Box 777 Mundelein, IL 600601919 Contact: Henry Dudzie (847) 837-0777	(2) <u>FACILITY</u> - name and address where tanks are located: Park Ridge BP (GEI-183) 1220 West Touhy Avenue Park Ridge, IL 60068 Contact: Kris Bernatek (847) 837-0785
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 4,000, (TK # 3) - 6,000, (TK # 4) - 8,000, (TK # 5) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2, 3, 4, 5) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 2, 3, 4, 5) Piping - Other submersible pump, (TK # 2, 3, 4, 5) Piping - Shear Valves, (TK # 2, 3, 4, 5) Piping - Valves Ball Valve, (TK # 2, 3, 4, 5) Piping - Dispenser Sumps Bravo B-1000 Series, (TK # 2, 3, 4, 5) Piping - Submersible Sumps Bravo B-400 Series*
- (d) *Product to be stored in each tank: (TK # 2, 3, 4, 5) - Gasoline*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 2, 3, 4, 5) Leak Detect - Piping - Electronic Pressurized Line Leak Detection Veeder Root TLS 350, (TK # 2, 3, 4, 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Customer wants to re-pipe site. Remove steel product piping and install double wall fiberglass along with new dispenser sumps.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


DRW Services, Inc.

Contact Person: Douglas Harmon

600 East Joe Orr Road
Chicago Heights, IL 60411

Phone: (708) 758-3222
Contractor Registration # IL194 Exp. 3/10/2016

Sincerely,

A handwritten signature in cursive script, reading "Daniel G. Starks", is written over a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File