



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

<p align="center">FOR OFFICE USE ONLY</p> <p>Facility # 2010502 Permit # 00232-2016UPG Request Rec'd 03/02/2016 Amended Date Approval Date 3/2/2016 DS Permit Expires 9/2/2016</p>

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 33978 N. US Hwy 45 Gages Lake, IL 600300089</p> <p>Contact: Mike Graham (847) 223-3710 Ext. 15</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Arlington Heights South Citgo 1650 West Algonquin Road Arlington Heights, IL 60005</p> <p>Contact: John Gardner (847) 223-8602</p>
--	--

- (3) UPGRADE OR REPAIR OF TANKS:**
- (a) Number and size of tanks being upgraded or repaired: (TK # 3, 4, 5) - 10,000*
 - (b) Type of tanks:*
 - (c) Type of piping: (TK # 3, 4, 5) Piping - Fiberglass Single Wall Piping Ameron Dualoy 3000L single wall fiberglass piping, (TK # 3, 4, 5) Piping - Shear Valves, (TK # 3, 4, 5) Piping - Dispenser Sumps Bravo B-1000 Series*
 - (d) Product to be stored in each tank: (TK # 3, 4, 5) - Gasoline*
 - (e) Type of leak detection being used:*
 - Tank:*
 - Piping:*
 - (f) Corrosion Protection being used:*
 - Tank:*
 - Piping:*
 - (g) Spill containment devices, piping, and dispenser containmnt devices:*
 - (h) Overfill prevention devices:*
 - (i) Manway accessible at grade:*
- (4)** The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.
- (5) SPECIAL CONTINGENCIES :** Install Bravo fiberglass dispenser sumps Install OPW 1-1/2" double poppet shear valves Re-connect single wall fiberglass to sumps

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
<p>DRW Services, Inc. 600 East Joe Orr Road Chicago Heights, IL 60411</p>	<p>Contact Person: Douglas Harmon Phone: (708) 758-3222 Contractor Registration # IL194 Exp. 3/10/2016</p>

Sincerely,

Daniel G. Starks

Daniel Starks

cc: Storage Tank Safety Specialist
Division File