



City of Chicago
 Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

FOR OFFICE USE ONLY
 Facility # 2044126
 Permit # 00271-2016REM
 Request Rec'd 03/15/2016
 Amended Date
 Approval Date 3/16/2016
 Permit Expires 9/16/2016

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Cook County Department Facilities Management 69 West Washington Street, 30th Floor Chicago, IL 60602</p> <p>Contact: Pat McCarthy (773) 674-7532</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Cook County Division 4 2717-00I 16 S. Sacramento Chicago, IL 60623</p> <p>Contact: Patrick Nolan (773) 869-5588</p>
---	--

(3) REMOVAL OF TANKS:


- (a) *Number and size of tanks being removed: (TK # 1) - 5,000*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - Diesel Fuel*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - Unknown*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) SPECIAL CONTINGENCIES :

<p>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></p>	
<p>Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107</p>	<p>Contact Person: Robert Sumoski Phone: (630) 497-9009 Contractor Registration # IL002345 Exp. 6/15/2017</p>

Sincerely,



Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
 Division File