



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 5027551
Permit # 00282-2016UPG
Request Rec'd 03/17/2016
Amended Date
Approval Date 3/17/2016 DS
Permit Expires 9/19/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity: Jack Flash Properties, LLC P.O. Box 217 Effingham, IL 62401 Contact: Lisa Wortman (217) 342-1000	(2) <u>FACILITY</u> - name and address where tanks are located: Jack Flash 30239 W. Frontage Rd. Farmersville, IL 62533 Contact: Kevin Guinn (217) 227-3134
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 5) - 12,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 5) Piping - Flexible Double Wall A.P.T. Poly Tech P175SC, (TK # 5) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series*
- (d) *Product to be stored in each tank: (TK # 5) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping: (TK # 5) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

- (5) **SPECIAL CONTINGENCIES** : New piping from dispenser sump under dispenser #9 to all dispensers on new island, with new dispenser sumps and new sensors as shown in site drawing

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

W J Scott Company
3861 Tozer Road
Springfield, IL 62707

Contact Person: James Scott
Phone: (217) 787-6081
Contractor Registration # IL1949 Exp. 2/28/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File