



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY
Facility # 2023159
Permit # 00284-2016UPG
Request Rec'd 03/17/2016
Amended Date
Approval Date 3/17/2016 DS
Permit Expires 9/19/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>Graham C-Stores Co. 33978 N. US Hwy 45 Gages Lake, IL 600300089</p> <p>Contact: Mike Graham (847) 223-3710 Ext. 15</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Dempster BP GCS-194 3301 West Dempster Skokie, IL 60076</p> <p>Contact: Felicia Campbell (847) 223-3710 Ext. 15</p>
--	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 10) - 15,000, (TK # 11) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping: (TK # 10, 11) Piping - Flexible Double Wall NUPI Smartflex, (TK # 10, 11) Piping - Dispenser Sumps Franklin Fueling Systems UPP Dispenser sump*
- (d) Product to be stored in each tank: (TK # 10, 11) - Gasoline*
- (e) Type of leak detection being used:*
Tank:
Piping: (TK # 10, 11) Leak Detect - Piping - Piping Sump Sensors Interstitial Monitoring Veeder Root TLS 350
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containmnt devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) **SPECIAL CONTINGENCIES** : Revising the existing DW flexible piping at all (10) existing dispenser islands to accomodate the installation of new Wayne Ovation dispensers. Re-configuring islands as shown on plans. Installing 1.5" DW Nupi Smartflex semi-rigid piping from the existing valve sumps at (5) North islands to facilitate spread on new dispensers. Installing (5) new VR sump sensors at the (5) new dispenser sumps. Revising the existing South valve sumps to be used as dispenser sumps (existing sensors to remain). Work to be performed in two phases so that facility can remain open.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:


Performance Tank, Inc.

Contact Person: Tim Berg

730 Creel Drive
Wood Dale, IL 60191

Phone: (630) 860-9500
Contractor Registration # IL881 Exp. 10/27/2016

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File