



City of Chicago
Department of Public Health
 333 South State Street, Room 200
 Chicago, IL 60604
 3127453152

FOR OFFICE USE ONLY
Facility # 2001281
Permit # 00289-2016UPG
Request Rec'd 03/11/2016
Amended Date
Approval Date 3/18/2016
Permit Expires 9/20/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) OWNER OF TANKS - Corporation, partnership, or other business entity:</p> <p>United States Postal Service 740 S. Canal St. Chicago, IL 606079401</p> <p>Contact: Jerry Averhart (312) 983-8702</p>	<p>(2) FACILITY - name and address where tanks are located:</p> <p>Central Vehicle Maintenance Facility 740 S Canal St Chicago, IL 60699</p> <p>Contact: Dennis Cheatham (312) 983-8710</p>
---	--

(3) UPGRADE OR REPAIR OF TANKS:

- (a) Number and size of tanks being upgraded or repaired: (TK # 5, 6, 7) - 20,000*
- (b) Type of tanks:*
- (c) Type of piping:*
- (d) Product to be stored in each tank: (TK # 5) - Gasoline, (TK # 6, 7) - Diesel Fuel*
- (e) Type of leak detection being used:*
Tank: (TK # 5, 6, 7) Leak Detect - Tank - Automatic Tank Gauging Veeder Root TCP/IP Interface Module
Piping:
- (f) Corrosion Protection being used:*
Tank:
Piping:
- (g) Spill containment devices, piping, and dispenser containment devices:*
- (h) Overfill prevention devices:*
- (i) Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Rick Krol Phone: (708) 478-6190 Contractor Registration # IL002275 Exp. 5/21/2016

Sincerely,


Chief Engineer-Storage Tank Section

Raul Valdivia

cc: Storage Tank Safety Specialist
Division File