



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
2177851020

**FOR OFFICE USE ONLY**

Facility # 2034987  
Permit # 00328-2016UPG  
Request Rec'd 03/26/2016  
Amended Date  
Approval Date 3/28/2016 DS  
Permit Expires 9/28/2016

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <b><u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:</p> <p>Operating Engineers Local 150 6200 Joliet Rd Countryside, IL 60525  Contact: Alicia Schnell (708) 482-8800</p>	<p>(2) <b><u>FACILITY</u></b> - name and address where tanks are located:</p> <p>Operating Engineers Local 150 6200 Joliet Rd Countryside, IL 60525  Contact: Alicia Schnell (708) 482-8800</p>
---	---

**(3) UPGRADE OR REPAIR OF TANKS:**

- (a) *Number and size of tanks being upgraded or repaired: (TK # 2) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/L, (TK # 2) Piping - Fiberglass Double Wall Ameron Dualoy 3000/LCX, (TK # 2) Piping - Dispenser Sumps A.P.T. Poly Tech Polyethylene LM Series, (TK # 2) Piping - Submersible Sumps Bravo B-400 Series*
- (d) *Product to be stored in each tank: (TK # 2) - Gasoline*
- (e) *Type of leak detection being used:*
  - Tank:*
  - Piping:*
- (f) *Corrosion Protection being used:*
  - Tank:*
  - Piping:*
- (g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 2) Spill Contain Device - Manhole Pre-manufactured EBW 705*
- (h) *Overfill prevention devices: (TK # 2) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-4000 overfill drop tube valve*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at [www.sfm.illinois.gov](http://www.sfm.illinois.gov) or by calling (217)785-1020.

**(5) SPECIAL CONTINGENCIES :**

UPGRADING EXISTING 10K UST, NEW EBW 705 SPILL BUCKET, NEW DISPENSER BOX, NEW AMERON LCX DW FRP EUROPEAN SAFE


SUCTION LINE, NEW AMERON FRP SINGLE WALL VENT LINE, NEW TANK SUMP, NEW SUCTION PUMP, NEW ISLAND, NEW TANK RISERS

**(6) PERSON, FIRM OR COMPANY PERFORMING WORK:**

Petroleum Technologies Equipment, Inc.  
8447 West 44th Place  
Lyons, IL 60534

Contact Person: Thomas J JR Doherty  
Phone: (708) 426-0400  
Contractor Registration # IL2051 Exp. 1/17/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

**cc:** Storage Tank Safety Specialist  
Division File