



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 6000108
Permit # 00341-2016UPG
Request Rec'd 03/30/2016
Amended Date
Approval Date 3/30/2016 DS
Permit Expires 9/30/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Mac's Convenience Stores, LLC P.O. Box 347 Columbus, IN 472020347 Contact: Matthew Jordan (812) 379-9227</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Quick Shop & Gas - 1374 601 West Main Collinsville, IL 62234 Contact: Jonathan Ross (812) 379-9227</p>
--	--

(3) UPGRADE OR REPAIR OF TANKS:

(a) *Number and size of tanks being upgraded or repaired: (TK # 3) - 10,000*

(b) *Type of tanks:*

(c) *Type of piping: (TK # 3) Piping - Galvanized Steel Single Wall Piping*

(d) *Product to be stored in each tank: (TK # 3) - Gasoline*

(e) *Type of leak detection being used:*

Tank:

Piping:

(f) *Corrosion Protection being used:*

Tank:

Piping:

(g) *Spill containment devices, piping, and dispenser containmnt devices: (TK # 3) Spill Contain Device - Manhole Pre-manufactured Emco Wheaton A1004*

(h) *Overfill prevention devices: (TK # 3) Overfill Prev Device - Overfill Drop Tube Valve OPW 71SO-410C overfill drop tube*

(i) *Manway accessible at grade:*

(4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.


(5) **SPECIAL CONTINGENCIES** : Replace existng fill riser, drop tube, and spill container with new. Will saw cut and break concrete and excavate to tank top to perform this work.

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.
5060 Arsenal Street
Saint Louis, MO 63139

Contact Person: Jimmy Spiros
Phone: (314) 772-4501
Contractor Registration # IL1502 Exp. 3/26/2018

Sincerely,



Daniel Starks

cc: Storage Tank Safety Specialist
Division File