



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2046114
Permit # 00355-2016REM
Request Rec'd 04/04/2016
Amended Date
Approval Date 4/5/2016 DS
Permit Expires 10/5/2016

Permit for REMOVAL of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to remove underground storage tank(s) or piping is hereby granted. Such removal shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, at which time the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>Depke Juvenile Justice Center, Lake County Facility Operations Lower Level 18 N. County Street Waukegan, IL 60085</p> <p>Contact: Jonathan Joy (847) 377-2457</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Depke Juvenile Justice Center, Lake County Facility Operations 24647 N. Milwaukee Ave. Vernon Hills, IL 60061</p> <p>Contact: Jonathan Joy (847) 377-2457</p>
--	--

(3) **REMOVAL OF TANKS:**

- (a) *Number and size of tanks being removed: (TK # 1) - 550*
- (b) *Description/location of piping being removed:*
- (c) *Product to be stored in each tank: (TK # 1) - #2 Fuel Oil*
- (d) *Reason of tanks being removed:*
- (e) *If tank(s) is leaking, indicate IEMA incident number:*
- (f) *Date each tank was last used: (TK # 1) - 12/31/1973*

(4) The owner must notify this Office when completion of tank removal has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at www.sfm.illinois.gov or by calling (217)785-1020. After removal is completed, the owner/operator shall perform a site assessment by measuring for the presence of a release where contamination is most likely to be present at the UST site. This is in accordance with the Illinois Administrative Code 176.360 (a) regulations and 40 CFR Part 280.72 (a) Federal Register Requirement.

(5) **SPECIAL CONTINGENCIES** : A 550 gallon heating oil UST was encountered while doing work at the property. The tank was filled with sand when encountered. The tank will be cleaned, the sand fill disposed of offsite, and the tank cut up and hauled off site for disposal.

(6) **PERSON, FIRM OR COMPANY PERFORMING WORK:**

The Lighthouse Companies
3120 Cottonwood Court
Highland Park, IL 60035

Contact Person: Alan Levine
Phone: (224) 619-4307
Contractor Registration # IL002409 Exp. 5/27/2017

Sincerely,

Daniel Starks

cc: Storage Tank Safety Specialist
Division File