



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
2177851020

FOR OFFICE USE ONLY

Facility # 2023271
Permit # 00384-2016UPG
Request Rec'd 04/07/2016
Amended Date
Approval Date 4/7/2016 DS
Permit Expires 10/7/2016

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances.

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall submit a required job schedule for underground piping upgrade, leak detection, spill and overfill prevention of underground storage tank(s) to the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety.

<p>(1) <u>OWNER OF TANKS</u> - Corporation, partnership, or other business entity:</p> <p>US Department of Energy 9800 S. Cass Ave. Argonne, IL 60439</p> <p>Contact: Kaushik Joshi (630) 252-4226</p>	<p>(2) <u>FACILITY</u> - name and address where tanks are located:</p> <p>Argonne National Laboratory 9700 S. Cass Ave. Argonne, IL 60439</p> <p>Contact: Gregg Kulma (630) 252-9147</p>
---	---

(3) UPGRADE OR REPAIR OF TANKS:

- (a) *Number and size of tanks being upgraded or repaired: (TK # 61, 63) - 10,000*
- (b) *Type of tanks:*
- (c) *Type of piping: (TK # 61, 63) Piping - Shear Valves*
- (d) *Product to be stored in each tank: (TK # 61) - Gasoline, (TK # 63) - Diesel Fuel*
- (e) *Type of leak detection being used:*
 - Tank:*
 - Piping:*
- (f) *Corrosion Protection being used:*
 - Tank:*
 - Piping:*
- (g) *Spill containment devices, piping, and dispenser containment devices:*
- (h) *Overfill prevention devices:*
- (i) *Manway accessible at grade:*

- (4) The owner must notify this Office when completion of tank upgrade/repair has occurred, on the Notification for Underground Storage Tank Form and the licensed contractor must submit the required job schedule for underground piping upgrade, leak detection, spill and overfill prevention to the OSFM prior to the work being performed. Both forms can be obtained at www.sfm.illinois.gov or by calling (217)785-1020.

(5) SPECIAL CONTINGENCIES :

Both diesel dispenser and Reg. Gasoline dispenser will have shear valves removed, re-installed at proper height per OSFM regulations.

Each existing valve is currently installed too low.

After re-assembly, both systems will be tested for proper operation.


NOTE: If there are no sumps existing then sumps MUST be installed per 175.410 d)

(6) PERSON, FIRM OR COMPANY PERFORMING WORK:

Accurate Tank Technologies, Inc.
204 Poplar Place
North Aurora, IL 60542

Contact Person: Steve Hirsch
Phone: (630) 375-6121 Ext. 10
Contractor Registration # IL1594 Exp. 2/23/2018

Sincerely,

A handwritten signature in cursive script that reads "Daniel G. Starks". The signature is written in dark ink and is positioned above a horizontal line.

Daniel Starks

cc: Storage Tank Safety Specialist
Division File